

BELDEN : Distributed by INTERSTATE WIRE CO., INC.

(800) 527-0010

3.30: Correction Factors for Table 4: Current Carrying Cap of 2 or 3 Cond

Number of Conductors	Reduction Percentage
4 thru 6	80%
7 thru 9	70%
10 thru 20	50%
21 thru 30	45%
31 thru 40	40%
41 and above	35%

If more than three (3) conductors are in a raceway, conduit or cable, the values given in Table 4 must be reduced using the above percentages.

(Example: The ampacity for 7 through 9 conductors = 70% of the value(s) shown in Table 4.